



**OFFICE OF THE DEPUTY FIRE OFFICER  
BALASORE CIRCLE, BALASORE.**

At - Balasore Fire Station Campus, in front of Town Hall, Balasore- 756001, Email- dfobls-ofs@gov.in

L. No-133/BLS.CLE

Dt-11.02.2025

To

Nimal Chandra Dhal, (Managing Trustee)  
Balasore Institute of Technical Studies,  
At/Po- Somanthpur, Ps- industrial Area,  
Dist- Balasore, .

Ref:- Ref Your online application No- FSC1102070102025000001 .

Sub - Fire Prevention & Fire Safety Measures & Issuance of Fire Safety Certificate of the G+1 storied building over Plot No- 284/300, 284/2, 285/1, Khata No - 118/14 & 118/15, Mouza- Guhalgaon, PS- Industrial, Dist- Balasore for an educational Institute in the name "Balasore Institute of Technical Studies" - Regarding.

Sir,

With reference to the subject cited above, it is to intimate that as per the OFP & FS Rules, 2017 r/w the OFP & FS (Amendment) Rules, 2019, the following classes of Educational Buildings are likely to have risk of fire & shall, at all times, have a valid Fire Safety Certificate:

- (i) Educational Buildings having a height of twelve meters and above, or
- (ii) having a built-up area of one thousand square meters or above, or
- (iii) having three storied building.


Whereas, the aforesaid building was inspected by a team on 11.02.2025 and its structural parameters are doesn't meet the above-mentioned criteria i.e the building height is less than twelve meters, less than three storied building & total built up area is less than one thousand square meters.

**In view of the above, as per the Odisha Fire Prevention and Fire safety Rules 2017 r/w the Odisha Fire Prevention and Fire safety Rules (Amendment) Rules, 2019, the aforesaid building (Balasore Institute of Technical Studies) doesn't come under the classes of Educational Buildings which required a Fire Safety Certificate.**

Whereas, it is advised that required Fire Prevention and Fire Safety Measures shall be provided in the building confirming to National Building Code of India for safety of life and property.

In the event of any change/addition/alteration (either structural or in use other than that intimate to this office) in the building or any information provided by the applicant is not found to be true, this letter shall be cancelled or treated as cancelled, as the case may be.

Yours Faithfully

  
( S.K Behera )

Deputy Fire Officer  
Balasore Circle, Balasore  
Balasore Circle, Balasore